



## PERTH AMBOY PUBLIC SCHOOLS BUILDINGS & GROUNDS DEPARTMENT

### Administrative Headquarters Building

178 Barracks Street  
Perth Amboy, NJ 08861  
Phone: (732) 376-6200 ext. 30-281  
Fax: (732) 638-1010

**Miguel Carmona, CEFM**  
District Director of Operations

**Luis A. Carrillo, Jr.**  
Operations Manager

**Melvin L Cruz, CEFM**  
Head of Maintenance

### Notice of Lead Testing Results in Drinking Water

5/30/2025

Dear Perth Amboy School District Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community, in accordance with the Department of Education regulations at N.J.A.C. 6A:26-12.4 **Edmund Hmielecki** recently completed testing for lead in drinking water throughout our school facilities.

In accordance with the Department of Education regulations, **Edmund Hmielecki** will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a *"DO NOT DRINK – SAFE FOR HANDWASHING ONLY"* sign will be posted.

#### **Results of our Testing**

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within **Edmund Hmielecki**. Through this effort, we identified and tested all drinking water and food preparation outlets.

#### **Summary of Results:**


Testing Date: 4/25/2025

Total Outlets Tested: 39

Number of Outlets Above Action Level: 1

You may view the full test results on our website at:

<https://www.paps.net/Page/18663>



## PERTH AMBOY PUBLIC SCHOOLS BUILDINGS & GROUNDS DEPARTMENT

### Administrative Headquarters Building

178 Barracks Street  
Perth Amboy, NJ 08861  
Phone: (732) 376-6200 ext. 30-281  
Fax: (732) 638-1010

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead with the associated first draw and follow-up flush sample lead levels, as well as what temporary remedial action DLS has taken or plans to take to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	Follow-up flush Result in µg/l (ppb)	Remedial Action
Nurse Office Sink ID#EHECC-NS-29	228	N/A	Immediately ceased potable usage. Posted signage "DO NOT DRINK- SAFE FOR HANDWASHING ONLY"

The following actions were taken regarding DLS lead in school drinking water exceedances:

1. Immediately ceased potable usage. Posted signage "DO NOT DRINK- SAFE FOR HANDWASHING ONLY"
2. Alternate drinking water is being provided to students and staff of the school from other existing outlets tested below lead action levels.

### Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At very high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

### How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers, and lakes. Lead enters drinking water primarily because of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes, and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning may contain fairly high levels of lead.



## **PERTH AMBOY PUBLIC SCHOOLS BUILDINGS & GROUNDS DEPARTMENT**

### **Administrative Headquarters Building**

178 Barracks Street  
Perth Amboy, NJ 08861  
Phone: (732) 376-6200 ext. 30-281  
Fax: (732) 638-1010

#### **Lead in Drinking Water**

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

#### **For More Information**

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 3:30 p.m. and are also available on our website at <https://www.paps.net/Page/18663>.

We are committed to providing a safe and healthy learning environment. If you have any questions, please contact Melvin L Cruz, Head of Maintenance at 732.376.6200 Ext. 30281 or [melvicruz@paps.net](mailto:melvicruz@paps.net).

Sincerely,  
Miguel Carmona, CEFM  
District Director of Operations



Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Edmund Hmieleski	4/25/2025	5/7/2025	1	EHECC-B-1	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	2	EHECC-B-2	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	3	EHECC-B-3	1.29
Edmund Hmieleski	4/25/2025	5/7/2025	4	EHECC-B-4	1.02
Edmund Hmieleski	4/25/2025	5/7/2025	5	EHECC-B-5	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	6	EHECC-B-6	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	7	EHECC-B-7	5.56
Edmund Hmieleski	4/25/2025	5/7/2025	8	EHECC-B-8	7.1
Edmund Hmieleski	4/25/2025	5/8/2025	9	EHECC-B-9	9.91
Edmund Hmieleski	4/25/2025	5/7/2025	10	EHECC-B-10	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	11	EHECC-B-11	1.21
Edmund Hmieleski	4/25/2025	5/7/2025	13	EHECC-FP-13	2.44
Edmund Hmieleski	4/25/2025	5/7/2025	14	EHECC-B-14	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	15	EHECC-B-15	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	16	EHECC-B-16	1.82
Edmund Hmieleski	4/25/2025	5/7/2025	17	EHECC-B-17	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	18	EHECC-B-18	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	19	EHECC-B-19	1.59
Edmund Hmieleski	4/25/2025	5/7/2025	20	EHECC-B-20	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	21	EHECC-B-21	1.58
Edmund Hmieleski	4/25/2025	5/7/2025	22	EHECC-B-22	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	24	EHECC-WC-24	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	25	EHECC-BF-25	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	26	EHECC-TL-26	2.23
Edmund Hmieleski	4/25/2025	5/7/2025	27	EHECC-WC-27	<1.00
Edmund Hmieleski	4/25/2025	5/8/2025	29	EHECC-NS-29	228
Edmund Hmieleski	4/25/2025	5/7/2025	30	EHECC-B-30	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	31	EHECC-B-31	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	32	EHECC-B-32	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	33	EHECC-B-33	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	34	EHECC-B-34	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	35	EHECC-B-35	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	36	EHECC-B-36	3.84
Edmund Hmieleski	4/25/2025	5/7/2025	37	EHECC-B-37	<1.00
Edmund Hmieleski	4/25/2025	5/7/2025	38	EHECC-B-38	1.56
Edmund Hmieleski	4/25/2025	5/8/2025	39	QAQC-BLANK	<1.00



7469 Whitepine Rd  
North Chesterfield, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

Client: LEW Corp  
181 US Hwy 46  
Mine Hill, NJ 07803

Report Number: 25-05-00204

Received Date: 05/01/2025  
Reported Date: 05/08/2025  
Sampled By: Marvin Ayumbi  
Tech Certification #:

Project/Test Address: 2389; Edmund Hmielecki; 925 Amboy Ave; Perth Amboy, NJ

Client Number:  
201327

## Laboratory Results

Fax Number:  
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
25-05-00204-001	1	04/25/2025	EHECC-B-1	<1.00	05/07/2025	
25-05-00204-002	2	04/25/2025	EHECC-B-2	<1.00	05/07/2025	
25-05-00204-003	3	04/25/2025	EHECC-B-3	1.29	05/07/2025	
25-05-00204-004	4	04/25/2025	EHECC-B-4	1.02	05/07/2025	
25-05-00204-005	5	04/25/2025	EHECC-B-5	<1.00	05/07/2025	
25-05-00204-006	6	04/25/2025	EHECC-B-6	<1.00	05/07/2025	
25-05-00204-007	7	04/25/2025	EHECC-B-7	5.56	05/07/2025	
25-05-00204-008	8	04/25/2025	EHECC-B-8	7.10	05/07/2025	
25-05-00204-009	9	04/25/2025	EHECC-B-9	9.91	05/08/2025	
25-05-00204-010	10	04/25/2025	EHECC-B-10	<1.00	05/07/2025	
25-05-00204-011	11	04/25/2025	EHECC-B-11	1.21	05/07/2025	
25-05-00204-012	13	04/25/2025	EHECC-FP-13	2.44	05/07/2025	
25-05-00204-013	14	04/25/2025	EHECC-B-14	<1.00	05/07/2025	

# Environmental Hazards Services, L.L.C

Client Number: 201327  
 Project/Test Address: 2389; Edmund Hmielecki; 925 Amboy Ave; Perth  
 Amboy, NJ

Report Number: 25-05-00204

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
25-05-00204-014	15	04/25/2025	EHECC-B-15	<1.00	05/07/2025	
25-05-00204-015	16	04/25/2025	EHECC-B-16	1.82	05/07/2025	
25-05-00204-016	17	04/25/2025	EHECC-B-17	<1.00	05/07/2025	
25-05-00204-017	18	04/25/2025	EHECC-B-18	<1.00	05/07/2025	
25-05-00204-018	19	04/25/2025	EHECC-B-19	1.59	05/07/2025	
25-05-00204-019	20	04/25/2025	EHECC-B-20	<1.00	05/07/2025	
25-05-00204-020	21	04/25/2025	EHECC-B-21	1.58	05/07/2025	
25-05-00204-021	22	04/25/2025	EHECC-B-22	<1.00	05/07/2025	
25-05-00204-022	24	04/25/2025	EHECC-WC-24	<1.00	05/07/2025	
25-05-00204-023	25	04/25/2025	EHECC-BF-25	<1.00	05/07/2025	
25-05-00204-024	26	04/25/2025	EHECC-TL-26	2.23	05/07/2025	
25-05-00204-025	27	04/25/2025	EHECC-WC-27	<1.00	05/07/2025	
25-05-00204-026	29	04/25/2025	EHECC-NS-29	228	05/08/2025	
25-05-00204-027	30	04/25/2025	EHECC-B-30	<1.00	05/07/2025	
25-05-00204-028	31	04/25/2025	EHECC-B-31	<1.00	05/07/2025	
25-05-00204-029	32	04/25/2025	EHECC-B-32	<1.00	05/07/2025	
25-05-00204-030	33	04/25/2025	EHECC-B-33	<1.00	05/07/2025	
25-05-00204-031	34	04/25/2025	EHECC-B-34	<1.00	05/07/2025	
25-05-00204-032	35	04/25/2025	EHECC-B-35	<1.00	05/07/2025	
25-05-00204-033	36	04/25/2025	EHECC-B-36	3.84	05/07/2025	

## Environmental Hazards Services, L.L.C


Client Number: 201327  
Project/Test Address: 2389; Edmund Hmielecki; 925 Amboy Ave; Perth  
Amboy, NJ

Report Number: 25-05-00204

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
25-05-00204-034	37	04/25/2025	EHECC-B-37	<1.00	05/07/2025	
25-05-00204-035	38	04/25/2025	EHECC-B-38	1.56	05/07/2025	
25-05-00204-036	39	04/25/2025	QAQC-BLANK	<1.00	05/08/2025	

Method: EPA 200.8  
Analyst: Nicole Holloway  
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:



Tasha Eaddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND      ug/L= micrograms per liter      ppb = parts per billion