



PERTH AMBOY PUBLIC SCHOOLS
BUILDINGS & GROUNDS DEPARTMENT

Administrative Headquarters Building

178 Barracks Street
Perth Amboy, NJ 08861
Phone: (732) 376-6200 ext. 30-281
Fax: (732) 638-1010

Miguel Carmona, CEFM

District Director of Operations

Luis A. Carrillo, Jr.

Operations Manager

Melvin L Cruz, CEFM

Head of Maintenance

Notice of Lead Testing Results in Drinking Water

5/30/2025

Dear Perth Amboy School District Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community, in accordance with the Department of Education regulations at N.J.A.C. 6A:26-12.4, **Ignacio Cruz** recently completed testing for lead in drinking water throughout our school facilities.

We are pleased to report that all water outlets tested were below the action level of 15 parts per billion (ppb). No further action is required at this time.

Summary of Results:

Testing Date: 4/26/2025

Total Outlets Tested: 41

Number of Outlets Above Action Level: 0

You may view the full test results on our website at:

<https://www.paps.net/Page/18663>

We are committed to providing a safe and healthy learning environment. If you have any questions, please contact Melvin L Cruz, Head of Maintenance at 732.376.6200 Ext. 30281 or melvicruz@paps.net.

Sincerely,

Miguel Carmona, CEFM

District Director of Operations

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Ignacio Crus	4/26/2025	5/8/2025	1	ICE-B-1	<1.00
Ignacio Crus	4/26/2025	5/8/2025	2	ICE-BF-2	<1.00
Ignacio Crus	4/26/2025	5/8/2025	3	ICE-B-3	<1.00
Ignacio Crus	4/26/2025	5/8/2025	4	ICE-B-4	<1.00
Ignacio Crus	4/26/2025	5/8/2025	5	ICE-B-5	1.72
Ignacio Crus	4/26/2025	5/8/2025	6	ICE-B-6	<1.00
Ignacio Crus	4/26/2025	5/8/2025	7	ICE-B-7	<1.00
Ignacio Crus	4/26/2025	5/8/2025	8	ICE-B-8	1.71
Ignacio Crus	4/26/2025	5/8/2025	9	ICE-B-9	<1.00
Ignacio Crus	4/26/2025	5/8/2025	10	ICE-B-10	<1.00
Ignacio Crus	4/26/2025	5/8/2025	11	ICE-B-11	2.31
Ignacio Crus	4/26/2025	5/8/2025	12	ICE-B-12	1.32
Ignacio Crus	4/26/2025	5/8/2025	13	ICE-B-13	<1.00
Ignacio Crus	4/26/2025	5/8/2025	16	ICE-B-16	<1.00
Ignacio Crus	4/26/2025	5/8/2025	17	ICE-B-17	<1.00
Ignacio Crus	4/26/2025	5/8/2025	18	ICE-B-18	<1.00
Ignacio Crus	4/26/2025	5/8/2025	19	ICE-B-19	<1.00
Ignacio Crus	4/26/2025	5/8/2025	19A	ICE-B-19A	<1.00
Ignacio Crus	4/26/2025	5/8/2025	20	ICE-NS-20	5.26
Ignacio Crus	4/26/2025	5/8/2025	21	ICE-NS-21	<1.00
Ignacio Crus	4/26/2025	5/8/2025	22	ICE-NS-22	2.1
Ignacio Crus	4/26/2025	5/8/2025	23	ICE-S-23	<1.00
Ignacio Crus	4/26/2025	5/8/2025	24	ICE-BF-24	<1.00
Ignacio Crus	4/26/2025	5/8/2025	25	ICE-S-25	1.68
Ignacio Crus	4/26/2025	5/8/2025	27	ICE-WC-27	<1.00
Ignacio Crus	4/26/2025	5/8/2025	28	ICE-WC-28	<1.00
Ignacio Crus	4/26/2025	5/8/2025	30	ICE-B-30	<1.00
Ignacio Crus	4/26/2025	5/8/2025	31	ICE-B-31	1.27
Ignacio Crus	4/26/2025	5/8/2025	32	ICE-B-32	1.87
Ignacio Crus	4/26/2025	5/8/2025	33	ICE-B-33	<1.00
Ignacio Crus	4/26/2025	5/8/2025	34	ICE-B-34	<1.00
Ignacio Crus	4/26/2025	5/9/2025	35	ICE-B-35	2.51
Ignacio Crus	4/26/2025	5/9/2025	36	ICE-B-36	1.17
Ignacio Crus	4/26/2025	5/8/2025	37	ICE-B-37	<1.00
Ignacio Crus	4/26/2025	5/8/2025	38	ICE-B-38	<1.00
Ignacio Crus	4/26/2025	5/8/2025	39	ICE-B-39	<1.00
Ignacio Crus	4/26/2025	5/8/2025	60	ICE-B-40	<1.00
Ignacio Crus	4/26/2025	5/8/2025	42	ICE-B-42	<1.00
Ignacio Crus	4/26/2025	5/8/2025	43	ICE-B-43	1.6
Ignacio Crus	4/26/2025	5/8/2025	45	ICE-B-45	<1.00
Ignacio Crus	4/26/2025	5/8/2025	46	ICE-B-46	<1.00
Ignacio Crus	4/26/2025	5/8/2025	47	QA/QC-BLANK	<1.00



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 25-05-00192

Received Date: 05/01/2025

Reported Date: 05/12/2025

Sampled By: Marvin Ayumbi

Tech Certification #:

Project/Test Address: 2389; Ignacio Crus; 601 Courtland Street; Perth Amboy, NJ

Client Number:

201327

Laboratory Results

Fax Number:

Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
25-05-00192-001	1	04/26/2025	ICE-B-1	<1.00	05/08/2025	
25-05-00192-002	2	04/26/2025	ICE-BF-2	<1.00	05/08/2025	
25-05-00192-003	3	04/26/2025	ICE-B-3	<1.00	05/08/2025	
25-05-00192-004	4	04/26/2025	ICE-B-4	<1.00	05/08/2025	
25-05-00192-005	5	04/26/2025	ICE-B-5	1.72	05/08/2025	
25-05-00192-006	6	04/26/2025	ICE-B-6	<1.00	05/08/2025	
25-05-00192-007	7	04/26/2025	ICE-B-7	<1.00	05/08/2025	
25-05-00192-008	8	04/26/2025	ICE-B-8	1.71	05/08/2025	
25-05-00192-009	9	04/26/2025	ICE-B-9	<1.00	05/08/2025	
25-05-00192-010	10	04/26/2025	ICE-B-10	<1.00	05/08/2025	
25-05-00192-011	11	04/26/2025	ICE-B-11	2.31	05/08/2025	
25-05-00192-012	12	04/26/2025	ICE-B-12	1.32	05/08/2025	
25-05-00192-013	13	04/26/2025	ICE-B-13	<1.00	05/08/2025	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 25-05-00192

Project/Test Address: 2389; Ignacio Crus; 601 Courtland Street; Perth Amboy, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
25-05-00192-014	16	04/26/2025	ICE-B-16	<1.00	05/08/2025	
25-05-00192-015	17	04/26/2025	ICE-B-17	<1.00	05/08/2025	
25-05-00192-016	18	04/26/2025	ICE-B-18	<1.00	05/08/2025	
25-05-00192-017	19	04/26/2025	ICE-B-19	<1.00	05/08/2025	
25-05-00192-018	19A	04/26/2025	ICE-B-19A	<1.00	05/08/2025	
25-05-00192-019	20	04/26/2025	ICE-NS-20	5.26	05/08/2025	
25-05-00192-020	21	04/26/2025	ICE-NS-21	<1.00	05/08/2025	
25-05-00192-021	22	04/26/2025	ICE-NS-22	2.10	05/08/2025	
25-05-00192-022	23	04/26/2025	ICE-S-23	<1.00	05/08/2025	
25-05-00192-023	24	04/26/2025	ICE-BF-24	<1.00	05/08/2025	
25-05-00192-024	25	04/26/2025	ICE-S-25	1.68	05/08/2025	
25-05-00192-025	27	04/26/2025	ICE-WC-27	<1.00	05/08/2025	
25-05-00192-026	28	04/26/2025	ICE-WC-28	<1.00	05/08/2025	
25-05-00192-027	30	04/26/2025	ICE-B-30	<1.00	05/08/2025	
25-05-00192-028	31	04/26/2025	ICE-B-31	1.27	05/08/2025	
25-05-00192-029	32	04/26/2025	ICE-B-32	1.87	05/08/2025	
25-05-00192-030	33	04/26/2025	ICE-B-33	<1.00	05/08/2025	
25-05-00192-031	34	04/26/2025	ICE-B-34	<1.00	05/08/2025	
25-05-00192-032	35	04/26/2025	ICE-B-35	2.51	05/09/2025	
25-05-00192-033	36	04/26/2025	ICE-B-36	1.17	05/09/2025	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 25-05-00192

Project/Test Address: 2389; Ignacio Crus; 601 Courtland Street; Perth Amboy, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
25-05-00192-034	37	04/26/2025	ICE-B-37	<1.00	05/08/2025	
25-05-00192-035	38	04/26/2025	ICE-B-38	<1.00	05/08/2025	
25-05-00192-036	39	04/26/2025	ICE-B-39	<1.00	05/08/2025	
25-05-00192-037	60	04/26/2025	ICE-B-40	<1.00	05/08/2025	
25-05-00192-038	42	04/26/2025	ICE-B-42	<1.00	05/08/2025	
25-05-00192-039	43	04/26/2025	ICE-B-43	1.60	05/08/2025	
25-05-00192-040	45	04/26/2025	ICE-B-45	<1.00	05/08/2025	
25-05-00192-041	46	04/26/2025	ICE-B-46	<1.00	05/08/2025	
25-05-00192-042	47	04/26/2025	QA/QC-BLANK	<1.00	05/08/2025	

Method: EPA 200.8

Analyst: Nicole Holloway

Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion