



Perth Amboy Public Schools

Administrative Headquarters Building
178 Barracks Street
Perth Amboy, NJ 08861
(732) 376-6200

Michael LoBrace
Business Administrator
Board Secretary



June 12, 2023

SAMUEL E SHULL MIDDLE SCHOOL
380 Hall Avenue
Perth Amboy, NJ 08861

Dear Perth Amboy Board of Education School Community:

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, the district tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Samuel E. Shull Middle School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Testing Results

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the district. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 75 samples taken, all but 0 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action the Perth Amboy School District has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
N/A	N/A	N/A

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.



Perth Amboy Public Schools

Administrative Headquarters Building
178 Barracks Street
Perth Amboy, NJ 08861
(732) 376-6200

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

For more information about water quality in our schools, contact Carmen Southward, District Director of Operations, at (732) 376-6200.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

A handwritten signature in blue ink, appearing to read "LoBrace", is written over the name and title of the signatory.

Michael LoBrace
Business Administrator/Board Secretary
Perth Amboy Board of Education



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

1/26/2022

Phone: (856) 840-8800
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 1/11/2022. The results are tabulated on the attached data pages for the following client designated project:

21-211/Shull Middle

The reference number for these samples is EMSL Order #012200793. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description 2 SES-SB-G16 G16		Collected: 1/11/2022 9:55:00 AM		Lab ID: 012200793-0001	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:22
Client Sample Description 3 SES-SB-G13 G13		Collected: 1/11/2022 9:57:00 AM		Lab ID: 012200793-0002	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:26
Client Sample Description 4 SES-SB-G35 G35		Collected: 1/11/2022 9:58:00 AM		Lab ID: 012200793-0003	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:28
Client Sample Description 5 SES-SB-G26 G26		Collected: 1/11/2022 9:59:00 AM		Lab ID: 012200793-0004	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:32
Client Sample Description 6 SES-SB-G34 G34		Collected: 1/11/2022 10:00:00 AM		Lab ID: 012200793-0005	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:34

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
Fax: (856) 840-8815
Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description 7 SES-SB-G27 G27		Collected: 1/11/2022 10:01:00 AM		Lab ID: 012200793-0006	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:36
Client Sample Description 8 SES-WC-HG27 Hallway hear G27		Collected: 1/11/2022 10:03:00 AM		Lab ID: 012200793-0007	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:37
Client Sample Description 9 SES-SB-G28 G28		Collected: 1/11/2022 10:03:00 AM		Lab ID: 012200793-0008	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:39
Client Sample Description 10 SES-SB-G33 G33		Collected: 1/11/2022 10:04:00 AM		Lab ID: 012200793-0009	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:40
Client Sample Description 11 SES-SB-G32 G32		Collected: 1/11/2022 10:04:00 AM		Lab ID: 012200793-0010	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:42

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
Fax: (856) 840-8815
Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description 12 SES-SB-G29 G29		Collected: 1/11/2022 10:05:00 AM		Lab ID: 012200793-0011	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:43
Client Sample Description 13 SES-SB-G30 G30		Collected: 1/11/2022 10:08:00 AM		Lab ID: 012200793-0012	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:51
Client Sample Description 14 SES-SB-G31 G31		Collected: 1/11/2022 10:08:00 AM		Lab ID: 012200793-0013	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:53
Client Sample Description 15 SES-SB-R134 RM134		Collected: 1/11/2022 10:30:00 AM		Lab ID: 012200793-0014	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:54
Client Sample Description 16 SES-SB-R137 RM137		Collected: 1/11/2022 10:31:00 AM		Lab ID: 012200793-0015	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 19:56

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description		17 SES-WC-H137 Hallway near RM 137	Collected:		1/11/2022 10:32:00 AM	Lab ID:		012200793-0016	
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Lead	ND	1.00 µg/L		1/21/2022	KB	1/24/2022 19:57	KB	
Client Sample Description		18 SES-SB-R138 RM 138	Collected:		1/11/2022 10:34:00 AM	Lab ID:		012200793-0017	
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Lead	ND	1.00 µg/L		1/21/2022	KB	1/24/2022 19:59	KB	
Client Sample Description		19 SES-SB-R147 RM147	Collected:		1/11/2022 10:35:00 AM	Lab ID:		012200793-0018	
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Lead	ND	1.00 µg/L		1/21/2022	KB	1/24/2022 20:00	KB	
Client Sample Description		20 SES-SB-R148 RM 148	Collected:		1/11/2022 10:36:00 AM	Lab ID:		012200793-0019	
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Lead	ND	1.00 µg/L		1/21/2022	KB	1/24/2022 20:02	KB	
Client Sample Description		21 SES-WC-HGYM Hall near Gym	Collected:		1/11/2022 10:17:00 AM	Lab ID:		012200793-0020	
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Lead	2.38	1.00 µg/L		1/21/2022	KB	1/24/2022 20:04	KB	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description		23 SES-SF-NURSEO RM 117-Nurse's Office		Collected:	1/11/2022 10:17:00 AM	Lab ID:	012200793-0021	
Method	Parameter	Result		RL Units		Prep Date & Analyst	Analysis Date & Analyst	
METALS								
200.8	Lead	ND		1.00 µg/L		1/21/2022 KB	1/24/2022 20:24	KB
Client Sample Description		24 SES-SF-NURSELUNCH RM 117-Nurse's Lunch Room		Collected:	1/11/2022 10:17:00 AM	Lab ID:	012200793-0022	
Method	Parameter	Result		RL Units		Prep Date & Analyst	Analysis Date & Analyst	
METALS								
200.8	Lead	1.50		1.00 µg/L		1/21/2022 KB	1/24/2022 20:29	KB
Client Sample Description		26 SES-SF-R168 RM 168 (Teacher's Lounge)		Collected:	1/11/2022 10:39:00 AM	Lab ID:	012200793-0023	
Method	Parameter	Result		RL Units		Prep Date & Analyst	Analysis Date & Analyst	
METALS								
200.8	Lead	ND		1.00 µg/L		1/21/2022 KB	1/24/2022 20:30	KB
Client Sample Description		27 SES-WC-H124 Hallway near RM 124		Collected:	1/11/2022 10:23:00 AM	Lab ID:	012200793-0024	
Method	Parameter	Result		RL Units		Prep Date & Analyst	Analysis Date & Analyst	
METALS								
200.8	Lead	ND		1.00 µg/L		1/21/2022 KB	1/24/2022 20:32	KB
Client Sample Description		28 SES-SB-R124 RM 124		Collected:	1/11/2022 10:24:00 AM	Lab ID:	012200793-0025	
Method	Parameter	Result		RL Units		Prep Date & Analyst	Analysis Date & Analyst	
METALS								
200.8	Lead	1.14		1.00 µg/L		1/21/2022 KB	1/24/2022 20:33	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
Fax: (856) 840-8815
Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description		29 SES-SB-R125 RM 125	Collected:		1/11/2022 10:25:00 AM	Lab ID:		012200793-0026	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 20:38	KB
Client Sample Description		30 SES-SB-R126 RM 126	Collected:		1/11/2022 10:26:00 AM	Lab ID:		012200793-0027	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 20:40	KB
Client Sample Description		31 SES-SB-R129 RM 129	Collected:		1/11/2022 10:27:00 AM	Lab ID:		012200793-0028	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 20:41	KB
Client Sample Description		32 SES-SB-R130 RM 130	Collected:		1/11/2022 10:28:00 AM	Lab ID:		012200793-0029	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 20:43	KB
Client Sample Description		33 SES-SB-R133 RM 133	Collected:		1/11/2022 10:30:00 AM	Lab ID:		012200793-0030	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 20:44	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description 34 SES-SF-K3 Kitchen - Triple Tub Sink (Left)		Collected: 1/11/2022 10:12:00 AM		Lab ID: 012200793-0031	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 20:46
Client Sample Description 35 SES-SF-K2 Kitchen - Double Tube Sink		Collected: 1/11/2022 10:12:00 AM		Lab ID: 012200793-0032	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 20:51
Client Sample Description 36 SES-SF-K1 Kitchen - Single Sink		Collected: 1/11/2022 10:13:00 AM		Lab ID: 012200793-0033	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.48	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 20:52
Client Sample Description 37 SES-SB-R212 RM 212		Collected: 1/11/2022 9:50:00 AM		Lab ID: 012200793-0034	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 20:57
Client Sample Description 40 SES-SB-R209 RM 209		Collected: 1/11/2022 9:40:00 AM		Lab ID: 012200793-0035	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 20:58

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
Fax: (856) 840-8815
Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description		41 SES-SB-R240 RM 240	Collected:		1/11/2022 9:41:00 AM	Lab ID:		012200793-0036	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:00	KB
Client Sample Description		42 SES-SB-R239 RM 239	Collected:		1/11/2022 9:42:00 AM	Lab ID:		012200793-0037	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:01	KB
Client Sample Description		43 SES-SF-R238 RM 238 (Teacher's Conf.)	Collected:		1/11/2022 9:43:00 AM	Lab ID:		012200793-0038	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		1.08	1.00 µg/L		1/21/2022	KB	1/24/2022 21:03	KB
Client Sample Description		44 SES-SB-R237 RM 237	Collected:		1/11/2022 9:44:00 AM	Lab ID:		012200793-0039	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:04	KB
Client Sample Description		45 SES-SB-R236 RM 236	Collected:		1/11/2022 9:45:00 AM	Lab ID:		012200793-0040	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:06	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
Fax: (856) 840-8815
Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description		46 SES-SB-R231 RM 231	Collected:		1/11/2022 9:46:00 AM	Lab ID:		012200793-0041	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:15	KB
Client Sample Description		47 SES-SB-R230 RM 230	Collected:		1/11/2022 9:47:00 AM	Lab ID:		012200793-0042	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:20	KB
Client Sample Description		48 SES-SB-R226 RM 226	Collected:		1/11/2022 9:48:00 AM	Lab ID:		012200793-0043	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:22	KB
Client Sample Description		49 SES-WC-H225 Hallway near RM 225	Collected:		1/11/2022 9:28:00 AM	Lab ID:		012200793-0044	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:23	KB
Client Sample Description		50 SES-SB-R225 RM 225	Collected:		1/11/2022 9:29:00 AM	Lab ID:		012200793-0045	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:25	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description		51 SES-SB-R224 RM 224	Collected:		1/11/2022 9:30:00 AM	Lab ID:		012200793-0046	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:26	KB
Client Sample Description		52 SES-SB-R221 RM 221	Collected:		1/11/2022 9:31:00 AM	Lab ID:		012200793-0047	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:28	KB
Client Sample Description		53 SES-SB-R223 RM 223	Collected:		1/11/2022 9:33:00 AM	Lab ID:		012200793-0048	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:29	KB
Client Sample Description		54 SES-SB-R218 RM 218	Collected:		1/11/2022 9:35:00 AM	Lab ID:		012200793-0049	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:34	KB
Client Sample Description		55 SES-SB-R217 RM 217	Collected:		1/11/2022 9:36:00 AM	Lab ID:		012200793-0050	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:36	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description		56 SES-SB-R214 RM 214	Collected:		1/11/2022 9:37:00 AM	Lab ID:		012200793-0051	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:37	KB
Client Sample Description		57 SES-SB-R213 RM 213	Collected:		1/11/2022 9:38:00 AM	Lab ID:		012200793-0052	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:42	KB
Client Sample Description		58 SES-SB-R314 RM 314	Collected:		1/11/2022 9:11:00 AM	Lab ID:		012200793-0053	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:43	KB
Client Sample Description		59 SES-SB-R313 RM 313	Collected:		1/11/2022 9:13:00 AM	Lab ID:		012200793-0054	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:45	KB
Client Sample Description		60 SES-SB-R312 RM 312	Collected:		1/11/2022 9:14:00 AM	Lab ID:		012200793-0055	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 21:46	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description		61 SES-WC-HGIRLS3 Hallway near 3rd FI Girl's RR		Collected:	1/11/2022 9:14:00 AM	Lab ID:	012200793-0056	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	ND	1.00 µg/L	1/21/2022	KB	1/24/2022 21:48	KB	
Client Sample Description		62 SES-SB-R310 RM 310		Collected:	1/11/2022 9:15:00 AM	Lab ID:	012200793-0057	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	ND	1.00 µg/L	1/21/2022	KB	1/24/2022 21:56	KB	
Client Sample Description		63 SES-SB-R309 RM 309		Collected:	1/11/2022 9:16:00 AM	Lab ID:	012200793-0058	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	ND	1.00 µg/L	1/21/2022	KB	1/24/2022 21:57	KB	
Client Sample Description		64 SES-SB-R344 RM 344		Collected:	1/11/2022 9:18:00 AM	Lab ID:	012200793-0059	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	ND	1.00 µg/L	1/21/2022	KB	1/24/2022 21:59	KB	
Client Sample Description		65 SES-SB-R343 RM 343		Collected:	1/11/2022 9:18:00 AM	Lab ID:	012200793-0060	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	ND	1.00 µg/L	1/21/2022	KB	1/24/2022 22:00	KB	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description 66 SES-SF-R342T **Collected:** 1/11/2022 **Lab ID:** 012200793-0061
 RM 342 - Teach'r 9:20:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 22:07

Client Sample Description 67 SES-SB-R341 **Collected:** 1/11/2022 **Lab ID:** 012200793-0062
 RM 341 9:22:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 22:14

Client Sample Description 68 SES-SB-R340 **Collected:** 1/11/2022 **Lab ID:** 012200793-0063
 RM 340 9:23:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 22:16

Client Sample Description 69 SES-SB-R334 **Collected:** 1/11/2022 **Lab ID:** 012200793-0064
 RM 334 9:24:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 22:17

Client Sample Description 70 SES-SB-R333 **Collected:** 1/11/2022 **Lab ID:** 012200793-0065
 RM 333 9:25:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 22:19

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description 71 SES-SB-R331 RM 331		Collected: 1/11/2022 9:25:00 AM		Lab ID: 012200793-0066	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 22:21
Client Sample Description 72 SES-SB-R329 RM 329		Collected: 1/11/2022 9:27:00 AM		Lab ID: 012200793-0067	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 22:22
Client Sample Description 73 SES-SB-R330 RM 330		Collected: 1/11/2022 9:28:00 AM		Lab ID: 012200793-0068	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 22:24
Client Sample Description 74 SES-WC-H328 Hallway near RM 328		Collected: 1/11/2022 9:00:00 AM		Lab ID: 012200793-0069	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.32	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 22:25
Client Sample Description 75 SES-SB-R328 RM 328		Collected: 1/11/2022 8:58:00 AM		Lab ID: 012200793-0070	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/21/2022 KB	1/24/2022 KB 22:30

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
Fax: (856) 840-8815
Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description		76 SES-SB-R327 RM 327	Collected:		1/11/2022 9:01:00 AM	Lab ID:		012200793-0071	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 22:31	KB
Client Sample Description		77 SES-SB-R321 RM 321	Collected:		1/11/2022 9:02:00 AM	Lab ID:		012200793-0072	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 22:36	KB
Client Sample Description		78 SES-SB-R325 RM 325	Collected:		1/11/2022 9:03:00 AM	Lab ID:		012200793-0073	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 22:38	KB
Client Sample Description		79 SES-SB-R324 RM 324	Collected:		1/11/2022 9:04:00 AM	Lab ID:		012200793-0074	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 22:39	KB
Client Sample Description		80 SES-SB-R318 RM 318	Collected:		1/11/2022 9:07:00 AM	Lab ID:		012200793-0075	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 22:41	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012200793

CustomerID: TTIE54

CustomerPO: 034117

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
Fax: (856) 840-8815
Received: 1/11/2022 01:30 PM

Project: 21-211/Shull Middle

Analytical Results

Client Sample Description		81 SES-SB-R323 RM 323	Collected:		1/11/2022 9:08:00 AM	Lab ID:		012200793-0076	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 22:42	KB
Client Sample Description		82 SES-SB-R317 RM 317	Collected:		1/11/2022 9:10:00 AM	Lab ID:		012200793-0077	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 22:44	KB
Client Sample Description		83 FIELD BLANK BLANK	Collected:		1/11/2022	Lab ID:		012200793-0078	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		1/21/2022	KB	1/24/2022 22:49	KB

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results